


SUBMITTAL DATA SHEET

Concentric Vent Kits



Part No.	A	B Nominal PVC Pipe Size	C	D	E	F
22152	33" (840mm)	2"	3.5" (89mm)	17.5" (445mm)	4.85" (123mm)	1.2" (30.5mm)
22153	39" (990mm)	3"	4.5" (114mm)	22" (559mm)	5.5" (140mm)	1.6" (41mm)
22154	57.25" (1455mm)	4"	5.5" (140mm)	39.25" (997mm)	8.1" (206mm)	4.35" (111mm)

- Do not use the Concentric Vent kit for anything other than a Category IV heater. Failure to follow this warning could result in fire, personal injury or death.
- Do not operate the heater until the installation and assembly of the Concentric Vent and all piping are completed. Failure to follow this warning could result in product damage or improper operation, personal injury or death.
- Recirculation of flue gasses may occur, causing the intake pipe to freeze shut during cold weather operation if the venting system is not installed per these guidelines.

Material: Polyvinyl Chloride (PVC)

Finish: Plain White

Standard: ASTM D1785, UL 1738.

NOTE: The Concentric Vent reduces the allowable intake/vent piping length by 5 feet from that listed in the basic heater installation instructions.



WARNING: Birth Defects, Reproductive Harm, and Cancer. www.p65warnings.ca.gov.